



Product Approval
USER: Public User

OFFICE OF THE
SECRETARY

[Product Approval Menu](#) > [Product or Application Search](#) > [Application List](#) > **Application Detail**

FL #	FL24001-R1
Application Type	Revision
Code Version	2023
Application Status	Approved

*Approved by DBPR. Approvals by DBPR shall be reviewed and ratified by the POC and/or the Commission if necessary.

Comments
Archived



Product Manufacturer	Transamerican Strukturoc, Inc.
Address/Phone/Email	920 Apollo Road, Suite 120 Eagan, MN 55121 (952) 884-7694 smeyer@strukturoc.com

Authorized Signature	Steve Meyer smeyer@strukturoc.com
----------------------	--------------------------------------

Technical Representative	Steve Meyer
Address/Phone/Email	920 Apollo Road Ste. 120 Eagan, MN 55121 (952) 884-7694 smeyer@strukturoc.com

Quality Assurance Representative
Address/Phone/Email

Category	Panel Walls
Subcategory	Siding

Compliance Method	Evaluation Report from a Product Evaluation Entity
-------------------	--

Evaluation Entity	Miami-Dade BCCO - EVL
Quality Assurance Entity	IAPMO Quality Control Consultants, LLC
Quality Assurance Contract Expiration Date	12/31/2027
Validated By	IAPMO Uniform ES

Certificate of Independence

Referenced Standard and Year (of Standard)	<u>Standard</u>	<u>Year</u>
	ASTM E330	2014
	TAS 201	1994
	TAS 203	1994

Equivalence of Product Standards
Certified By

Sections from the Code

Product Approval Method

Method 1 Option C

Date Submitted

10/25/2024

Date Validated

10/28/2024

Date Pending FBC Approval

Date Approved

11/02/2024

Summary of Products

FL #	Model, Number or Name	Description
24001.1	Structuroc Force Five	Impact resistant 20 ga. Steel composite panel, fastened directly to steel supports or using steel hat channels. (Shutters not required)
Limits of Use Approved for use in HVHZ: Yes Approved for use outside HVHZ: Yes Impact Resistant: Yes Design Pressure: +75/-75 Other:		Installation Instructions FL24001_R1_II_SKM_C250j24100910540.pdf Verified By: Zachary R. Priest, PE FL-74021 Created by Independent Third Party: Yes Evaluation Reports FL24001_R1_AE_SKM_C250j24100910540.pdf

[Back](#)

[Next](#)

[Contact Us](#) :: 2601 Blair Stone Road, Tallahassee FL 32399 Phone: 850-487-1824

The State of Florida is an AA/EEO employer. [Copyright 2007-2013 State of Florida](#). :: [Privacy Statement](#) :: [Accessibility Statement](#) :: [Refund Statement](#)

Under Florida law, email addresses are public records. If you do not want your e-mail address released in response to a public-records request, do not send electronic mail to this entity. Instead, contact the office by phone or by traditional mail. If you have any questions, please contact 850.487.1395. *Pursuant to Section 455.275(1), Florida Statutes, effective October 1, 2012, licensees licensed under Chapter 455, F.S. must provide the Department with an email address if they have one. The emails provided may be used for official communication with the licensee. However email addresses are public record. If you do not wish to supply a personal address, please provide the Department with an email address which can be made available to the public. To determine if you are a licensee under Chapter 455, F.S., please click [here](#).

Product Approval Accepts:



Credit Card
Safe

securityMETRICS